



# ONDA<sup>®</sup>



**VALVE & WATER METER**

<https://watermeterindonesia.com>

**ROTARY-VANE DRY-DIAL  
MAGNET-DRIVE**

**WATER METER  
BRASS BODY**

**FEATURE :**

- \* Dry - Dial
- \* Multi - Jet
- \* Magnetic Drive
- \* B1 - Directional Flow
- \* Antimagnetic Construction
- \* Measuring accuracy conform to ISO 4064 class B standard

PRODUCT BY [PT. HARAPAN UTAMA INDONESIA](http://PT.HARAPAN_UTAMA_INDONESIA)



# ONDA®



**VALVE & WATER METER**

## # TECHNICAL DATA #

<b>Nominal Diameter</b>	<b>DN</b>	<b>mm</b>	<b>15</b>	<b>20</b>	<b>25</b>
<b>Nominal Pressure</b>	<b>PN</b>	<b>Bar</b>	<b>10</b>	<b>10</b>	<b>10</b>
<b>Smallest Readable</b>	<b>Vol.</b>	<b>l</b>	<b>0.1</b>	<b>0.1</b>	<b>0.1</b>
<b>Registration Capacity</b>		<b>m<sup>3</sup></b>	<b>99999</b>	<b>99999</b>	<b>99999</b>
<b>Operating Temperature</b>	<b>Max</b>	<b>C</b>	<b>50</b>	<b>50</b>	<b>50</b>
<b>Installation Position</b>	<b>Pipe</b>				
	<b>Meter</b>		←→	←→	←→
	<b>Head</b>		↑	↑	↑
<b>Maximal Flow Rate</b>	<b>Qmax</b>		<b>3</b>	<b>5</b>	<b>7</b>
<b>Nominal Flow Rate</b>	<b>Qn</b>		<b>1.5</b>	<b>2.5</b>	<b>3.5</b>
<b>Transitional Flow Rate</b>	<b>Qt</b>	<b>m<sup>3</sup> / h</b>	<b>0.12</b>	<b>0.20</b>	<b>0.28</b>
<b>Minimum Flow Rate</b>	<b>Qmin</b>		<b>0.03</b>	<b>0.05</b>	<b>0.07</b>
<b>Error Limits</b>	<b>Qmax..Qt</b>		<b>&lt; + 2</b>	<b>&lt; + 2</b>	<b>&lt; + 2</b>
	<b>Qmin</b>		<b>&lt; + 5</b>	<b>&lt; + 5</b>	<b>&lt; + 5</b>
<b>Dimensions in mm :</b>					
	<b>L :</b>		<b>165</b>	<b>190</b>	<b>260</b>
	<b>B :</b>		<b>99</b>	<b>99</b>	<b>104</b>
	<b>H :</b>		<b>104</b>	<b>106</b>	<b>120</b>

\* Subject to modification without notice

**AGEN :**

PRODUCT BY PT. HARAPAN UTAMA INDONESIA